



INSTALLATION NOTES

Flow and return pipework as per Boiler manufacturers recommendation.
Normally the minimum pipe size is 22mm.

A - This is a return flow when the Boiler is heating the domestic hot water only

B - This is a return flow when the Boiler is used for both, DHW and heating

JASPI UK www.jaspi.uk

Ultrastore 500 + Pellet Boiler
(with DHW priority control)

DRAWN	VERSION	DATE	DRAWING REF.
SS		05.01.2015	Generic